

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201230
Address: 612 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Thursday, May 28, 2020

Corrective Action Required:

1	Misc	Medical grade electrical needed for the lights in the exam rooms. --Above ceiling support MC to lights and junction box home runs. - all open wiring and boxed need to be close or cover plates installed. -- plumbing ok to cover
---	------	---

Comments: