## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRCOM20191681

Address: 560 NW CHIPMAN RD, LEES SUMMIT, MO 64086

Inspected On: Thursday, May 28, 2020

**Inspected By:** Mark Harding

Expiration Date: 6/11/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Mark Harding Temporary C of O Thursday, May 28,

Codes Commercial 2020

## Corrective Action Required:

1 Misc BUILDING INSPECTIONS LIST- OK FOR TCO-2WEEKS TO COMPLETE

THE FOLLOWING:

- ACCESS TO ROOF TOP FOR INSPECTION(WEATHER RELATED)

-GUARD RAIL OPENING AT LOADING DOCK OVER 4" NEXT TO

**BUILDING** 

-GFCI NEED WITHIN 6' OF MOP SINK.

-SUPPORTING OF DWV PIPE 48"O.C. OVER REAR COOLERS.

- JACKSON COUNTY HEALTH DEPT APPROVED 5/28

OTHER DEPARTMENTS ON SEPARATE LETTER.

ALL APPROVED FOR TCO.