

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193585  
Address: 2920 NW THOREAU DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:     | Outcome: | Date:                |
|---------------------------------|----------------|----------|----------------------|
| <b>DE - Sidewalk Inspection</b> | Ronald Paynter | Passed   | Friday, May 29, 2020 |

Informational:  
1 Misc Forms were placed and aggregate was present and compacted for the sidewalk right of the driveway. I informed them about broom finish for sidewalks. RP 5-20-20

Informational:  
2 Misc Finished sidewalk meets LS and ADA specs. RP 5-29-20

**Comments:**