

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200314
Address: 1708 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, May 29, 2020

Corrective Action Required:

1	Miscellaneous Correction	-COMPLETE GARAGE PORTAL Framing PFH PER DETAIL-NAILING PATTERN EXTERIOR, 5/8" ANCHOR BOLTS AND DOUBLE BOTTOM PLATE -MISSING ANCHOR BOLTS IN GARAGE -ANCHOR BOLTS WITHIN 12" OF PLATE BREAK -PROVIDE CLIP OR HANGER ON RAFTER IN OFFICE/BEDROOM WHERE UNLANDED RAFTER MEETS BEAM -NAIL DOUBLE 2x12 HEADERS TOGETHER IN MASTER BED -FINISH BLOCKING JOISTS ABOVE BEAM IN BASEMENT -COMPLETE GAS LINE AND HOOK UP ON EXTERIOR GAS FIREPLACE
---	--------------------------	--

Comments: