



CADSTONE STUDIO

1213 W 32nd Street Independence, MO 64055
816-550-0130 Cadstone1@aol.com

Date 05-28-2020

Joe Frogge
220 SE Green Street
Lee's Summit, MO 64063
816.969.1200
816.969.1201 Fax
cityofLS.net/Development

Permit No: PRCOM20201280
Project Title: SUMMIT FAIR - CORRIDOR ALTERATION
Project Address: 910 NW BLUE PKWY, LEES SUMMIT, MO 64086
Parcel Number: 51700033700000000

Location / Legal

Description:

SUMMIT FAIR, LOTS 31 & 32-PT LOT 32 DAF: BEG NW COR SE 1/4 SEC-36 TWP-48 RNG-32 TH S 2 DEG 28 MIN 52 SEC E & RAD 139') 74.01' TH S 00 DEG 57 MIN 28 SEC W 65.80' TH S 89 DEG 10 MIN 24 SEC E 231.21' TH S TH SELY ALG LF CURV (RAD 111') 67.86' TO POINT OF REVERSE CURV SELY & SLY ALG RI CURV (RAD 139') 85. W 44.01' TH S 79 DEG 07 MIN 37 SEC E 49.50' TH S 10 DEG 52 MIN 23 SEC W 54.98' TH S 2 DEG 59 MIN 20

Type of Work: ALTERATION COMMERCIAL

Occupancy Group:

Description: CORRIDOR ALTERATION

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Licensed Contractors Reviewed By: Joe Frogge Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company name of licensed HVAC contractor.

Response: The General Contractor will provide the city with a list of MEP subcontractors that will complete the work associated with this project.

Fire Plan Review Reviewed By: Michael Weissenbach Rejected

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Any modifications to the fire alarm system, provide electronic shop drawings to mike.weissenbach@cityofls.net

Response: Fire Protection drawings will be provided by fire sprinkler sub contractor under separate submittal indicating any modifications to existing system.

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide electronic shop drawings to mike.weissenbach@cityofls.net

Response: Fire Protection drawings will be provided by fire sprinkler sub contractor under separate submittal indicating any modifications to existing system.

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

Response: Noted

4. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

(Action Required)

Provide fire rating and door hardware for exit door.

Response: Door hardware and fire ratings noted on revised drawings dated 05-27-2020

Building Plan Review Reviewed By: Joe Frogge Rejected

1. ICC A117.1 Section 404.2.3.2 Swinging Doors and gates. Swinging doors and gates shall have maneuvering clearances

complying with Table 404.2.3.2.

Action required: Provide minimum 18" clearance at latch side of rear exit door.

Response: Modification to adjacent wall to meet these required distances on revised drawings dated 5-27-20

2. Inadequate information to complete review.

Actions required:

- Specify fire rating of wall
- Specify fire rating of new door
- Specify hardware for new door
- Provide complete UL details including nail/screw patterns.

Response: Door hardware, fire ratings and UL details added and noted on revised drawings dated 05-27-2020

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Sincerely,
Duane Hicks, R.A.



05-28-2020