



May 28, 2020

Mr. Chris Clark
Project Manager
A.J. Brown, Inc.
635 Trade Center Boulevard
Chesterfield, Missouri 63005

RE: Special Inspection Report No. 8
Goddard School
3395 NE Ralph Powell Road
Lee's Summit, Missouri
Report Period: March 29, 2020 to May 30, 2020
Building Permit #PRCOM20190683
Geotechnology, Inc. Project No.: J034913.01

Dear Mr. Clark:

This letter will constitute our Special Inspection transmittal for the above referenced project. Representatives of Geotechnology, Inc. have provided field observation and testing services for pavement subgrade during the report period. Our services have been provided on a part-time basis as scheduled by representatives of A.J. Brown, Inc. The compliance of materials or work not observed by our personnel is not addressed, or implied, by this or any previous report.

Summary of Activities

Pavement Subgrade

The moisture content and stability of the pavement subgrade were observed at the following locations:

April 2	- West parking lot north and south curb lines and center island
May 19	- West parking lot

The subgrades were proofrolled using a fully-loaded tandem-axle dump truck. The subgrades appeared stable during the evaluations.

Status of Compliance


The specific items discussed above in this report appeared to be in general compliance with the contract documents.

Closure

The results of our field observations and testing were reported to authorized personnel during our site visits. If you have any questions regarding this report, or if we may be of further service, please contact us.

Respectfully submitted,

GEOTECHNOLOGY, INC.



Peter F. Brull, P.E.
Senior Engineer

Steve Damron
CMT Department Manager

cc: Mr. Ryan Elam – City of Lee's Summit
Ms. Sara Beck – City of Lee's Summit
Mr. Jim Hostler – A.J. Brown, Inc.
Geotechnology S.I. File



**Goddard School
Variance/Discrepancy List**

NOTE: Items resolved during the report period are shaded

Variance Number	Date Opened	Date Closed	Description
-			