

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200943
Address: 1606 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|-----------|-----------------------|
| Underslab Plumbing Inspection - Residential | Robb Popp | Not Ready | Monday, June 01, 2020 |

Corrective Action Required:

| | | |
|---|------|----------------------------|
| 1 | Misc | NO INSPECTION PERFORMED |
| | | - POST ADDRESS - |
| | | —6-1-20— |
| | | -8 AM |
| | | -ADDRESS STILL NOT POSTED- |

Comments: