CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172519

Address: 237 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Michael Harkins Partial Tuesday, June 02, 2020

Commercial

Corrective Action Required:

1 LOWER LEVEL SOUTH END -

- 105 FIRE BLOCK DEAD SPACE/ FIRE COLLAR - - 107 FIRE BLOCK DEAD SPACE, / FIRE COLLAR -

- NORTH END -

- 101 FIRE COLLAR DEAD SPACE - 103 FIRE COLLAR DEAD SPACE -

Corrective Action Required:

2 FIRST FLOOR SOUTH END -

- 205 FIRE COLLAR DEAD SPACE, - - 207 FIRE COLLAR DEAD SPACE -

- NORTH END -

- 201 FIRE COLLAR DEAD SPACE - 203 FIRE COLLAR DEAD SPACE -

Corrective Action Required:

3 SECOND FLOOR SOUTH END -

- 305 FIRE COLLAR DEAD SPACE, ROOF BOOTS -

- 306 ROOF BOOTS -- 307 ROOF BOOTS -- 308 ROOF BOOTS -

- NORTH END -

- 301 FIRE COLLAR DEAD SPACE, BOCA PLATES CLOSET & TUB BATH -
- 302 ROOF BOOTS -
- 303 ROOF BOOTS, BOCA PLATE SPRINKLER LINE CLOSET, FIRE COLLAR DEAD SPACE -
- 304 ROOF BOOTS -

Comments: