

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191897
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Ronald Paynter	Partial	Tuesday, June 02, 2020

Corrective Action Required:

1	Misc	Same 2 troubled areas dumped silt into the roadways (the curve on Pergola Park and the corner of Mary and Redbuck). Please clean up the silt and install better erosion control devices. RP 5-26-20
---	------	---

Corrective Action Required:

2	Misc	David cleaned the silt up yesterday from the previous inspection, but today's rain has washed silt back out in those areas again. RP 5-28-20
---	------	--

Informational:

3	Misc	Silt has been removed from the roadways. RP 5-29-20
---	------	---

Informational:

4	Misc	Gordon Erosion is seeding and spreading straw on all remaining lots not under construction. RP 6-2-20
---	------	---

Comments: