

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200314  
Address: 1708 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Tuesday, June 02, 2020

Corrective Action Required:  
2 Miscellaneous —OK TO COVER—  
Correction

-COMPLETE GAS LINE AND ELECTRICAL HOOK UP ON EXTERIOR GAS FIREPLACE  
-UNDERGROUND ELECTRIC AND PLUMBING INSPECTION REQUIRED

**Comments:**