

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200943
Address: 1606 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, June 03, 2020

Corrective Action Required:

1	Misc	- COMPLETE INTERIOR DRAIN TILE LAYOUT AROUND PERIMETER OF FOUNDATION FOOTING, DRAIN TILE BUNCHED UP ACROSS MIDDLE OF BASEMENT -
---	------	---------------------------------------------------------------------------------------------------------------------------------

Comments: