

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Michael Harkins	Passed	Wednesday, June 03, 2020

Informational:	
1 Misc	NE CORNER B-B.5 1-4 STEM WALL REBAR (3) # 4 BARS 12 OC
Informational:	
2 Misc	- STEM WALL LINE 8 WEST WALL, SOUTH WALL , EAST WALL COMPLETES STEM WALL-
	- UFER LOCATED SE CORNER -

Comments: