

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192522
Address: 2911 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, June 04, 2020

Corrective Action Required:

1	Misc	- SPLASH BLOCKS/EXTENSIONS REQUIRED AT ALL DOWNSPOUT LOCATIONS, MINIMUM 36" DISTANCE FROM FOUNDATION - - SECURITY SCREWS AT BACK DOOR, (2) 3" SCREWS AT LATCH SIDE
---	------	--

Comments: