CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201144

Address: 2939 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Plumbing Inspection Patrick Schonfeldt Failed Thursday, June 04,

- Residential 2020

Corrective Action Required:

1 Misc - UNABLE TO INSPECT ALL DWV DUE TO MUD WATER COVER FROM HEAVY

RAINS. PUMP OUT WATER OR WAIT TO RESCHEDULE WHEN CONDITIONS

ALLOW FOR A COMPLETE INSPECTION - ENSURE ALL DWV IS LYING ON GRAVEL BED

Comments: