

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20193630
Address: 1812 SW RIVER RUN DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed - Stop Work	Wednesday, February 12, 2020

Corrective Action Required
1 Misc

Provide address -
Provide erosion control & gravel filter -
Provide 3rd party inspection within 48 hours of inspection -
Provide engineers report for compaction -
Letter needs to address frost footing at walkout -
2/11/20
EMAIL & CALL BUILDER NO CONTACT FOOTING & FOUNDATION
POURED WITHOUT APPROVAL NO ENGINEER REPORT STOP
WORK ORDER ISSUED

Comments: