

# Inspection Summary

Permit #: PRCOM20191001, Building Permit - Commercial  
HT SOLUTIONS - ADDITION  
Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

## Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
Rough Electrical Inspection - Commercial Informational	Mark Harding	Passed	Thursday, June 04, 2020
1	All exterior wall electrical boxes are approved, need to cover ASAP as the MC lines are not rated to be outside in the weather, rain, etc. ok to cover		
Occupancy Inspection - Codes Commercial Informational	Mark Harding	Failed	Thursday, June 04, 2020
1	ALL BUILDING INSPECTION ITEMS COMPLETED. PENDING APPROVAL FROM OTHER DIVISIONS. INSPECTIONS APPROVED FOR C OF O.		
Occupancy Inspection - Planning	Hector Soto Jr.	Passed	Thursday, June 04, 2020
Occupancy Inspection - Field Services Informational	Steve Robbins	Failed	Thursday, June 04, 2020
1	The sidewalk needs to be installed or the UDO amendment needs to be approved and a payment in lieu of construction for the sidewalk needs to be made when approved.		

## Comments:

