

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200564  
Address: 1920 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Khanh Nguyen	Passed	Friday, June 05, 2020

Informational:  
1 Misc POOL BONDED: 4 SHELL REBAR BONDED AT 4 EQUALLY SPACED POINTS  
AROUND POOL; HANDRAIL, LADDER, JUMPER TO EQUIPMENT LOCATION, DECK  
PERIMETER REBAR

**Comments:**