

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20192218  
Address: 1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Erosion Sediment Control (ESC) Inspection</b>	Joe Starlin	Partial	Friday, June 05, 2020

Informational:	
1 Misc	3-17-20 All erosion controls appear to be in place and holding.
Informational:	
2 Misc	3-18-20 After todays rain there will need to be more erosion controls added around the east walking path and by the park parking lot.
Informational:	
3 Misc	4-20-20 8:16am All erosion controls are in place and appear to be working well. 5-6-20 All erosion controls in the park appear to be in place and working at this time. Rain is forecasted for 5-7-20. 5-26-20 All erosion controls are in place and working at this time. 6-4-20 They will be removing some silt fence were vegetation has been established. 6-5-20 I met with the superintendent and we went over again the silt fence that will be removed band seeding the bare spots. They need to fill in around a tree where water is standing.

**Comments:**