

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20193625  
Address: 2050 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Street - Proof Roll</b>	Joe Starlin	Partial	Monday, June 08, 2020

Informational:

1 Misc

5-13-20 8:59am ESS proof rolled Two turn lanes on Pryor rd. They have both passed. Rain is moving in and the lanes will require a second proof roll with any rain fall. 6-8-20 We have proof rolled both turn lanes on Pryor and the drive at Pryor and Summit Wood. Private road C has passed as well.

**Comments:**