CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20182611 Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Rated Assembly Inspection		Robb Popp	Partial	Monday, June 08, 2020	
Partial Correction:					
2	STAIR TOWER 1	4TH FLOOR 1ST LAYER; - 4TH FLOOR 2ND LAYER - -CEILING AND WALL TOP C -CEILING AND WALLS 2ND MECHANICAL ROOMS 2NE	LAYER		
		3RD LAYER AND HAT CHAM	NNEL		
Partial Correction:					
3	STAIR TOWER 2	4TH FLOOR 1ST LAYER; - 2ND LAYER FLOORS 1-4 - -CEILING AND TOP OUT 1S CEILING AND WALLS 2ND I MECHANICAL ROOM 2ND 3RD LAYER AND HAT CHAN	LAYER LAYER CEILING		
Partial Correction:					
4	ELEVATOR 1	OK TO COVER WHEN READ ELEVATOR SHAFT:	DY 5/8" MOLD-RESISTANT FI	RECODE X GWB AT	
		1ST LAYER FLOORS: 1-4 CEILING:1ST, LAYER - 2ND LAYER FLOORS 1-4 CEILING 2ND LAYER - CEILING 3RD LAYER AND H	IAT CHANNEL		

CEILING 4TH LAYER

Partial Correction:	
5 FOURTH FLOOR	
Corrective Action Required:	
6 THIRD FLOOR	
Corrective Action Required:	
7 SECOND FLOOR	
Corrective Action Required:	
8 FIRST FLOOR	1ST FLOOR ELEC ROOM, IT ROOM, ELEV EQIP ROOMS 1ST LAYER -
Corrective Action Required:	
9 LOWER LEVEL	
Partial Correction:	
1 THE FOLLOWING	BEHIND TUBS AND SHOWERS FIRST LAYER FLOORS 1-4
AREAS ARE	BEHIND TUBS AND SHOWERS SECOND LAYER FLOORS 1-4
APPROVED	ELEVATOR AND STAIRWELL FIRST LAYER FLOORS 1-4
	SHEAR WALL FIRST LAYER BEHIND TUBS AND SHOWER FLOORS 1-2
	SHEAR WALL 6 FIRST LAYER OSB FLOORS 1-2
	SHEAR WALL4 FIRST LAYER
	SHEAR WALL 2 FIRST LAYER
	SHEAR WALL 6 FIRST LAYER
	ELEVATOR EQUIPMENT ROOM LOWER LEVEL FIRST LAYER
	MECHANICAL ROOM LOWER LEVEL FIRST LAYER
	CORRIDOR FIRST LAYER ROOM SIDE LOWER LEVEL AND FIRST FLOOR
	RC CHANNEL WALLS AND CEILING 4TH FLOOR
	RC CHANNEL WALLS AND CEILING 3RD FLOOR

Comments: