

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200416
Address: 1198 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, June 08, 2020

Corrective Action Required:

1	Misc	-FIRE DEPT APPROVAL REQUIRED. NO TCO -INSTALL FACE PLATE FOR RECEPTACLE LOCATED UNDER NORTH-SIDE COUNTER -INSTALL ADA COMPLIANT DOOR KNOB FOR THE RESTROOM THAT DOES NOT REQUIRE THE TWISTING OF THE HAND TO LOCK THE DOOR
---	------	--

Comments: