

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191098
Address: 4060 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, June 09, 2020

Corrective Action Required:

1	Misc	-Secure AC whip within 12" of disconnect
		-Identify receptacle in garage as non-gfci (label, marking, etc)
		-Secure fmc raceway within 12" of cooktop connection
		-Move water line min 1" away from b-vent
		**OK TO MOVE IN FURNITURE

Comments: