

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192817  
Address: 121 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Tuesday, June 09, 2020

Corrective Action Required:

1	Misc	- PROVIDE FINAL GRADE, SOD, SPLASH BLOCKS - - PROVIDE GUARD RAIL OR RAISE GRADE TO 30" @ FRONT STOOP - - PROVIDE GUARD RAIL AT WINDOW WELL WITHIN 3' OF PATIO WALKING SURFACE - - PROVIDE LOCKOUT DEVICE AT SERVICE PANEL FOR HARD WIRED APPLIANCES - - PROVIDE GFCI PROTECTION DISHWASHER -
---	------	--

Comments: