

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192817  
Address: 121 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Tuesday, June 09, 2020

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | - PROVIDE FINAL GRADE, SOD, SPLASH BLOCKS -<br>- PROVIDE GUARD RAIL OR RAISE GRADE TO 30" @ FRONT STOOP -<br>- PROVIDE GUARD RAIL AT WINDOW WELL WITHIN 3' OF PATIO WALKING SURFACE -<br>- PROVIDE LOCKOUT DEVICE AT SERVICE PANEL FOR HARD WIRED APPLIANCES -<br>- PROVIDE GFCI PROTECTION DISHWASHER - |
|---|------|--|

Comments: