

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172502
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Michael Harkins	Passed	Tuesday, June 09, 2020

Partial Correction:

1	Misc	VISUAL INSPECTION AND PRESSURE TEST OK ON 20 LF OF GAS LINE TRENCHED FROM FIRE PIT LOCATION TO GRILL LOCATION.
---	------	--

Partial Correction:

2	Misc	270' gas line from meter to firepit tracer wire in place provide guage & pressure for gas test - OK TO COVER BEFRORE RAIN -
---	------	---

Comments: