

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200309  
Address: 156 NW CARSON DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, June 10, 2020

Informational:	
1      Misc	- GARAGE PORTAL FRAME HOLDDOWNS NAILED OFF, NAILING PATTERN, HEADER TO KING STUD STRAPS, 5/8 ANCHOR BOLTS & DOUBLE BOTTOM PLATE, OK TO COVER

Corrective Action Required:	
2      Misc	- TIGHTEN ANCHOR BOLTS GARAGE & BASEMENT - - PROVIDE CS-PF PER PLAN PATIO DOOR - - FIRE BLOCK FIREPLACE IN CORNERS AT CEILING - - ADDRESS NOTCHED RIDGE ON HANGER ABOVE LIVING ROOM - - NO DECK PIER INSPECTION ON RECORD - : NOTE: HAMMER ARRESTOR IN WALL LAUNDRY :

**Comments:**