CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200384

Address: 3004 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Patrick Schonfeldt Failed Wednesday, June 10,

Residential 2020

Corrective Action Required:

1 Misc - Garage PFH per plans

- Truss H2.5 missing- garage, dining room, front entry
- Fireblock deadspace arch columns in dining room
- Secure and protect PEX at showers
- DWV boca protection plates bedroom #2 closet, PEX at laundry
- Security blocking at backdoor to deck
- Seal around Fireblock gaps at deadspace by kitchen entrance from hall
- Seal gaps at Fireblock edges at fireplace
- Secure Ward flex gas line at deck fireplace
- Remove cover at deck fireplace to allow for inspection of Fireblock
- Missing truss hanger per plan master bedroom
- Support DWV every 48" oc
- Complete DWV master bath
- Seal gaps at Fireblock between top plate and foundation basement
- Seal gaps at vertical Fireblock at studs basement

Comments: