

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20200315  
Address: 1828 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Thursday, June 11, 2020

Corrective Action Required:

1	Miscellaneous Correction	—THIS LIST IS INCOMPLETE— *****NO ACCESS TO BASEMENT***** -TIGHTEN ANCHOR BOLTS IN GARAGE -B VENT LESS THAN 1" CLEARANCE TO COMBUSTIBLES IN CHASE TOP PLATE -SEAL GAP AT TOP PLATE OF VENT CHASE -PROTECTION PLATE FOR ELECTRICAL IN LAUNDRY ROOM -PROTECT PEX LINES OUTSIDE OF LAUNDRY ROOM -PROTECTION PLATES FOR ELECTRICAL BY SLIDING DOOR/WINDOWS -ADDRESS OVER SIZED HOLES IN I JOISTS IN LIVING ROOM FOR DWV -WRONG HANGER AT DOUBLE 2X12 HEADER IN LOFT UPSTAIRS STAIR LANDING -PROTECTION PLATE FOR PEX LINE JACK AND JILL BATH
---	--------------------------	--

**Comments:**