

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201377
Address: 770 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mark Harding	Failed	Thursday, June 11, 2020

Corrective Action Required:

1	Misc	ONLY 1 GRAOUND ROD AND 100 AMP BREAKER. NO CURCUITS. CONTACT OFFICE AND ADD A SCOPE OF WORK TO THE PERMIT WHAT THE ELECTRICAL IS FOR AND WHAT BRANCH CIRCUITS WILL BE USED. PLEASE PROVIDE A DETAILED DESCRIPTION OF WORK.
---	------	---

Comments: