

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200384
Address: 3004 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, June 12, 2020

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Truss H2.5 missing-dining room- Seal around Fireblock gaps at deadspace by kitchen entrance from hall- Seal gaps at Fireblock edges at fireplace- Seal romex penetration through Fireblock in deck fireplace- Missing truss hanger per plan master bedroom |
|---|------|--|

Comments: