

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192668
Address: 1825 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Patrick Schonfeldt	Failed	Friday, June 12, 2020

Corrective Action Required:

1	Misc	- slope falls off at back of lot and yard is flat at back of house. Concerned not enough positive drainage away from house and potential for pooling exists. -
---	------	--

Comments: