

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20192617  
Address: 2013 NE BLUESTONE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Friday, June 12, 2020

Corrective Action Required:

1 Miscellaneous  
Correction

Corrective Action Required:

2 Miscellaneous Correction

- SEAL ALL EXTERIOR PENETRATIONS
- PROVIDE PROPER DRAINAGE AWAY FROM FOUNDATION FOR SUMP DISCHARGE
- PROVIDE GFCI IN LAUNDRY ROOM
- PROVIDE GFCI PROTECTION FOR DISHWASHER
- REMOVE SET SCREW IN ANTI SYPHON DEVICE
- PROVIDE EGRESS LADDERS FOR WINDOW WELLS
- COMPLETE MINERAL WOOL OVER DUCTWORK IN NORTH UNFINISHED BASEMENT

Comments: