

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201062
Address: 1804 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Friday, June 12, 2020

Corrective Action Required:

1	DCM3 Erosion Control	-EROSION CONTROL REQUIRED. -REESTABLISH SILT FENCE AT FRONT AND BACK OF LOT -PROVIDE GRAVEL FILTER AT DRIVE -RESOLVE BEFORE ANY FURTHER INSPECTIONS
---	----------------------	--

Comments: