

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192861
Address: 2919 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, June 15, 2020

Corrective Action Required:

1	Misc	- Complete patio door lock - Two locking devices required at sliding patio door - 20 AMP GARAGE CIRCUIT AND OUTLETS SHALL BE REQUIRED PER NEC 2017, 210.11 (C)(4) AND 210.52 (G)(1) - Attic access cover required in Laundry - Complete final grade and sod - Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"
---	------	--

Comments: