

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200445  
Address: 1000 NE COLBERN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Robb Popp	Partial	Monday, June 15, 2020

Partial Correction:

1 Misc

UNDERSLAB PLUMBING OK BELOW:  
-2" WATER SERVICE LINE INTO THE BUILDING  
-3 RESTROOMS AND ABOUT 100 FT OF BUILDING DRAIN STARTING FROM  
SEWER CLEANOUT  
-STORM SEWER NORTH SIDE  
-STORAGE AREA FLOOR DRAIN AND HAND SINK NE CORNER  
-

**Comments:**