

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192808
Address: 152 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Partial	Monday, June 15, 2020

Informational:

1 Misc

Forms were placed and aggregate was present and compacted. I informed them that they need to remove curbing joint to joint (they left a 4 ft section in). They will also be using white cure for the curbing. RP 6-15-20

Comments: