## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRCOM20192495Address:2931 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial		Robb Popp	Partial	Monday, June 15, 2020
Corrective	Action Required:			
1	Miscellaneous	-LINES FROM METER CAN	BEHIND DUMPSTER TO SERV	ICE AT BUILDING:
	Correction	FUTURE LINES NORTH TO	CORNER OF BUILDING ABOU	IT 6' FROM FENCE.
		3 LIGHT POLES IN FRONT	PARKING FROM MONUMEN	SIGHN JUNCTION BOX
		WITH GROUND RODS		
		1 LIGHT POLE WITH GROU	IND ROD BY DUMPSTER PAD	

**Comments:**