

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200790
Address: 510 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Failed	Tuesday, June 16, 2020

Informational:

2	Miscellaneous Correction	Power from building to light pole nw corner of lot
---	-----------------------------	--

Corrective Action Required:

3	Miscellaneous Correction	-ALL UNDERGROUND ELECTRICAL IN PARKING LOTS REQUIRED TO. BE MIN. 24' DEEP
---	-----------------------------	--

Comments: