

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181586
Address: 1312 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, June 16, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Obtain lawn irrigation permit-Remove all debris from storm inlet-Provide full support underneath west deck post-Install backyard flood light-Install water hammering arrestor for dishwasher-Install anti backflow device at basement hose bib-Receptacle located within six ft of the wet bar sink must be gfci-protected-Screw the basement exterior door embedded brace into studs with 3" screws-Remove paper facing from insulation-Cut off the excess grounding rebar
---	------	---

Comments: