

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193576
Address: 2927 SW ARBORWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, June 16, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- GFCI protection at laundry- Complete patio door handle/lock, two locking devices required on sliding doors- Complete floor outlet living room- Security screws front door hinge, provide (2) 3" screws- Complete security light, back of house- Complete grade and sod- Seal all exterior penetrations- Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36" |
|---|------|---|

Comments: