

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20172527  
Address: 253 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Michael Harkins	Failed	Tuesday, June 16, 2020

Corrective Action Required:

1	FIRST FLOOR	- 101 LAND A/C CONDUCTORS - - FIRE COLLARS DEAD SPACE ALL UNITS - - INSTALL WINDOWS - - COMPLETE FRAMING ENTRYWAYS & LAND ALL CONDUCTORS IN A BOX -
---	-------------	--

Corrective Action Required:

2	SECOND FLOOR	- GFCI DECKS 201, 203, 205, 207, - - FIRE COLLARS DEAD SPACE ALL UNITS - - 202 LAND A/C CONDUCTORS, BOCA PLATE UTILITY CLOSET BOTTOM PLATE - - 203 FIRE CAULK BOTTOM PLATE @ DRYER VENT - - INSTALL WINDOWS -
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	- GFCI DECKS 301, 303, 305, 307, - - FIRE COLLARS IN DEAD SPACES ALL UNITS - - INSTALL WINDOWS -
---	-------------	--

**Comments:**