

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191159  
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mark Harding	Failed	Tuesday, June 16, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>*install approved restroom signage north bathrooms.</li><li>* install vertical grab bar 39-41" north restroom.</li><li>* complete concrete walk around north side of building.</li><li>* complete concrete at west exit at fence.</li><li>* Provide GFCI protection on Food truck 50 amp circuit east side of wave pool at pedestal.</li><li>* support and secrue DVW in pool room, at mid story and along wall.</li></ul> Provide approval from other City Divisions on seperate letter.
---	------	---

**Comments:**