

Inspection Summary

Permit #: PRCOM20191159, Building Permit - Commercial
SUMMIT WAVES - WAVE POOL
Address: 120 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Field Services	Steve Robbins	Failed	Tuesday, June 16, 2020

Corrective Action Required

1. Waiting on approved detention basin plan and as-builds. The structure has been built with un-approved plans. Waiting on the plans to be approved. 2. Final grading needs to be completed.

Comments: