

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20192617
Address: 2013 NE BLUESTONE DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, June 17, 2020
Inspected By: Khanh Nguyen
Expiration Date: 7/17/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Wednesday, June 17, 2020

Corrective Action Required:

2	Miscellaneous Correction	-LAG SCREW THE DECK LEDGER BOARD INTO RIM BAND PER CODE -COMPLETE MINERAL WOOL OVER DUCTWORK IN NORTH UNFINISHED BASEMENT **THROUGHOUT-INSTALL THE MINERAL WOOL TO BOTTOM OF THE TJI WEB. INSTALL SUPPORT WIRES REQUIRED PER PRODUCT INSTRUCTION -PROVIDE AFCI PROTECTION PER NEC 210.12. ALL OUTLETS LOCATED IN AREAS BESIDE CRAWL SPACE, UNFINISHED BASEMENT, OUTDOOR, ATTIC, GARAGE, AND BATHROOM ARE REQUIRED TO BE AFCI-PROTECTED
---	-----------------------------	---

-THE RECEPTACLE AT SUBPANEL NOT GFCI