

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200309
Address: 156 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Passed	Tuesday, June 16, 2020

Informational:	
1 Misc	- GARAGE PORTAL FRAME HOLDDOWNS NAILED OFF, NAILING PATTERN, HEADER TO KING STUD STRAPS, 5/8 ANCHOR BOLTS & DOUBLE BOTTOM PLATE, OK TO COVER

Comments: