

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182611
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Passed	Thursday, June 18, 2020

Corrective Action Required:

1	Miscellaneous Correction	SHEET ROCK AND FIRE CAULK ON CEILINGS AND WALLS FOR FURDOWNS IN G1 AND G17
---	--------------------------	--

Comments: