

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193634
Address: 3009 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, June 18, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Maintain erosion control until sod is placed- Sod- Obtain lawn irrigation system permit- Terminate and complete exterior light fixture at garage and back patio- Complete stone/siding front of house- Secure electrical whip at AC within 12" of disconnect- Cover plates required at all outlets - kitchen- No power at GFCI outlets to test, half bath at mud room, garage, front porch, 2nd floor baths- breakers missing from main and sub panel
---	------	--

Comments: