

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192156
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Michael Harkins	Partial	Thursday, June 18, 2020

Informational:
1 Misc 6 sections 1st layer wrap 4' from flange welds approved on all 6 sections
Informational:
2 Misc WELDS APPROVED HOOD DUCTS #4 #5 #6 (2 PCS)

Comments: