

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193472  
Address: 1243 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Thursday, June 18, 2020

Corrective Action Required:

1	Misc	- SECURE ALL MC CABLE WITHIN 12" OF JUNCTION BOX. -INSTALL BATH FAN IN RESTROOM. -COMPLETE ALL HVAC TO CEILING GRID, INSTALL RETURN AIR DUCT TO CEILING GRID( MAIN TRUNK LINE ONLY INSATALLED NO BRANCH RUNS)  NO LIGHTING PANELS INSTALLED.
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**