

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200707  
Address: 860 NW BLUE PKWY, Unit:U, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mark Harding	Failed	Thursday, June 18, 2020

Corrective Action Required:

1	Misc	--SUPPORT PEX WATER PIPE 32" HORIZONTAL . --SUPPORT DWV 48"O.C
---	------	---

FOR WALL ROUGH--  
INSTALL PLUMBING PROTECTION PLATES AT BOTTOM PLATE OF WALLS.

**Comments:**